



DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I

345 KEKŪANAŌ'A STREET, SUITE 20 • HILO, HAWAI'I 96720

TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY  
COUNTY OF HAWAI'I  
HILO, HAWAI'I

**ADDENDUM NO. 1**

JOB NO. 2016-1054

INVITATION FOR BIDS  
FOR THE

**‘ŌLA‘A #6 DEEPWELL REPAIR  
DISTRICT OF PUNA  
County of Hawai‘i – State of Hawai‘i**

The following revisions and changes shall be made a part of the contract bidding documents:

A. Changes to **SPECIAL PROVISIONS:**

1. Page SP-5: **DELETE & REPLACE** “SECTION 304.05 DEEPWELL SUBMERSIBLE PUMPING UNIT”, Item B.1.a.i.4), with the following:

“Pump shall be National *MI4MC* or approved equal. Minimum pump efficiency shall be 82.5 %. See item 6 CONTROL OF MATERIALS AND EQUIPMENT on page IB-11 for details.”

2. Page SP-13: **ADD** the following to the end of “SECTION 304.05 DEEPWELL SUBMERSIBLE PUMPING UNIT”, Item C.4.:

“m. Deepwell Control Valve (Solenoid Valve Support Plate and Fasteners).

- i. Support plate shall be type 316 stainless steel; size to match existing.
- ii. Support fasteners shall be stainless steel (hex posts shall be type 304; bolts and washers shall be type 316); size to match existing.
- iii. Coat all threads with a nickel or molybdenum disulfide based anti-seize compound prior to assembly and provide insulating washers to isolate all dissimilar metals.”

*...Water, Our Most Precious Resource...Ka Wai A Kāne...*


The Department of Water Supply is an Equal Opportunity provider and employer.

**B. CLARIFICATION:**

Page P-6, Part "C" (Materials), Item 10: This item only includes the replacement of the existing support plate and fasteners for the deepwell solenoid valve. All other components of the existing deepwell control valve shall remain.

BY AUTHORITY OF THE DEPARTMENT OF  
WATER SUPPLY COUNTY OF HAWAI'I

Date: September 30, 2016

By:   
Keith K. Okamoto, P.E., Manager-Chief Engineer

*Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.*

Receipt of a copy of **ADDENDUM NO. 1** for JOB NO. 2016-1054, 'ŌLA'A #6 DEEPWELL REPAIR, District of Puna, County of Hawai'i, State of Hawai'i, is hereby acknowledged.

\_\_\_\_\_  
NAME OF BIDDER

Date: \_\_\_\_\_

By: \_\_\_\_\_