



DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I

345 KEKŪANAŌ'A STREET, SUITE 20 • HILO, HAWAI'I 96720

TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY
COUNTY OF HAWAI'I
HILO, HAWAI'I

ADDENDUM NO. 2

JOB NO. 2016-1047

INVITATION FOR BIDS

FOR THE

**KALOKO MAUKA #3 BOOSTERS A & B REPAIR
DISTRICT OF NORTH KONA
County of Hawai'i – State of Hawai'i**

The following revisions and changes shall be made a part of the contract bidding documents:

Changes to **SPECIAL PROVISIONS:**

1. Page SP-5: **REVISE** Section 304.05 – “Booster Pumping Unit”, Section B.1, “Vertical Turbine Pump”, Item a.i.5. to **ADD** the following as an approved equal.

Ruhrpumpen 8A-15 has been approved as an approved equal manufacturer for the 125 GPM @ 610 ft. head vertical turbine pumps.

BY AUTHORITY OF THE DEPARTMENT OF
WATER SUPPLY COUNTY OF HAWAI'I

Date: June 8, 2016

By: 
Keith K. Okamoto, P.E., Manager-Chief Engineer

Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.

Receipt of a copy of **ADDENDUM NO. 2** for JOB NO. 2016-1047, KALOKO MAUKA #3 BOOSTERS A & B REPAIR, District of North Kona, County of Hawai'i, State of Hawai'i, is hereby acknowledged.

NAME OF BIDDER

Date: _____

By: _____

...Water, Our Most Precious Resource...Ka Wai A Kāne...

The Department of Water Supply is an Equal Opportunity provider and employer.